

Eddie Baza Calvo
Governor



Christine Baleto
Director, Dept. of Admin.

GENERAL SERVICES AGENCY
Government of Guam
18 Route 1 Marine Drive Corp
Piti, Guam 96915

Ray Tenorio
Lt. Governor

Deputy Director

January 10, 2017

INVITATION FOR BID GSA-011-17
New Score Board Installation Project
For DPR Tiyan and The Guerrero Little League Fields

Questions received from PolyPhase System 01/05/17

Question 1:

Request for a bid time extension for two (2) weeks due to holiday season.

Response: Refer to "Amendment 2" (attached)

Question 2:

Information of power supply connection for scoreboard for both Tiyan & Guerrero Fields.

Response: Power Supply Connection: Contractor shall be responsible for connecting Electrical Score Boards to nearest DPR existing power source. This may include, but not limited to, the installation of conduit and electrical wiring as well as separate electrical supply box, etc. Score boards must run independently from field lights. Contractors are advised that there is an existing power source feeding the field lights which are located adjacent to the proposed scoreboard site. Contractors are strongly encouraged to conduct their independent site inspection and assessment.

Question 3:

Clarify the number of scoreboards to be installed for both Tiyan & Guerrero Fields.


Response:

- (A) Tiyan Upper Softball Field (1 ea.)
- (B) Tiyan Lower Softball Field (1 ea.)
- (C) DPR Guerrero Little League Field (1 ea.)

Question 4:

Please confirm if we can still reuse and refurbish existing frame of Tiyan Fields or demolish/remove all the existing frame and its foundation of Tiyan Fields.

Response: Use of Existing Frames and Foundation at Tiyan: Contractors shall be required to remove existing metal scoreboard frames at all locations and install new frames and required foundations to support newly furnished scoreboards.


CLAUDIA S. ACFALLE
Chief Procurement Officer